

Broadway Water Treatment Plant

Year and Month	pH	Iron (mg/l)	Manganese (mg/l)	Color (units)	Turbidity (NTU)	Free Chlorine (mg/l)	Total Chlorine (mg/l)	Finished Water Gallons
Jan-17	7.75	0.025	0.013	0	0.08	0.96	1.02	5,100,170
Feb-17	7.85	0.025	0.016	1	0.1	0.85	0.97	5,810,353
Mar-17	7.88	0.021	0.03	1.1	0.11	0.75	0.92	4,342,840
Apr-17	8.06	0.013	0.031	0.4	0.12	0.99	1.1	1,356,950
May-17	7.79	0.017	0.026	0.5	0.09	1.01	1.15	10,050,148
Jun-17	7.77	0.02	0.017	0.8	0.1	0.93	1.08	9,389,497
Jul-17	7.75	0.026	0.03	0.8	0.09	0.92	1.07	10,986,511
Aug-17	7.84	0.026	0.017	0.1	0.09	0.93	1.07	14,650,549
Sep-17	7.81	0.028	0.014	0.4	0.09	0.88	1.02	12,243,694
Oct-17	7.64	0.022	0.015	0.3	0.08	0.94	1.1	7,794,088
Nov-17	7.71	0.019	0.018	0.6	0.08	0.93	1.15	7,124,984
Dec-17	7.69	0.027	0.014	0.3	0.08	0.93	1.1	9,721,707
Jan-18	7.73	0.026	0.013	0.4	0.08	0.9	1.09	10,959,586
Feb-18	7.68	0.023	0.014	0.3	0.09	0.96	1.16	8,665,393
Mar-18	7.66	0.025	0.016	0.1	0.08	0.9	1.09	10,250,119
Apr-18	7.65	0.022	0.012	0.3	0.07	0.99	1.13	12,716,259
May-18	7.73	0.025	0.012	0.2	0.08	1.18	1.37	12,010,194
Jun-18	7.76	0.022	0.022	0.3	0.08	1.14	1.33	11,847,544
Jul-18	7.7	0.02	0.017	0.3	0.09	1.14	1.35	9,832,427
Aug-18	7.71	0.028	0.013	0.3	0.09	1.12	1.32	9,740,407
Sep-18	7.75	0.017	0.014	0	0.08	1.11	1.31	9,118,909
Oct-18	7.79	0.028	0.015	1	0.09	1.15	1.34	6,830,890
Nov-18	7.83	0.026	0.02	1	0.08	1.38	1.59	7,029,026
Dec-18	7.78	0.025	0.022	1	0.09	1.3	1.51	7,775,874