

Pond Street Water Treatment Plant

Year and Month	pH	Iron (mg/l)	Manganese (mg/l)	Color (units)	Turbidity (NTU)	Free Chlorine (mg/l)	Total Chlorine (mg/l)	Finished Water Gallons
Jan-17	7.76	0.013	0.029	1.2	0.06	1.04	1.26	27,409,299
Feb-17	7.85	0.011	0.032	1	0.07	1.02	1.19	21,875,548
Mar-17	7.8	0.012	0.033	0.9	0.06	0.93	1.12	25,574,548
Apr-17	7.77	0.012	0.033	0.9	0.07	0.97	1.14	28,492,120
May-17	7.8	0.01	0.044	1.7	0.07	0.92	1.07	26,831,650
Jun-17	7.79	0.011	0.053	2.4	0.08	0.89	1.06	30,010,867
Jul-17	7.84	0.011	0.06	3.4	0.09	0.94	1.18	30,126,389
Aug-17	7.74	0.013	0.042	2.6	0.09	1.03	1.27	30,579,503
Sep-17	7.74	0.013	0.041	1.3	0.08	1.04	1.29	23,940,561
Oct-17	7.8	0.015	0.041	1.4	0.08	1.12	1.35	23,540,561
Nov-17	7.77	0.012	0.044	2.6	0.08	1.15	1.39	18,384,853
Dec-17	7.71	0.011	0.037	1.1	0.07	1.13	1.29	15,853,440
Jan-18	7.68	0.011	0.038	0.9	0.07	1.05	1.25	19,433,696
Feb-18	7.76	0.012	0.033	0.8	0.06	1.05	1.26	17,688,112
Mar-18	7.88	0.012	0.03	0.8	0.07	1.14	1.36	24,119,628
Apr-18	7.74	0.01	0.025	1.1	0.07	1.05	1.33	25,514,482
May-18	7.75	0.01	0.032	2.1	0.07	1.12	1.39	30,861,841
Jun-18	7.72	0.012	0.04	2.2	0.08	1.18	1.41	32,411,164
Jul-18	7.74	0.013	0.037	2.1	0.08	1.18	1.47	33,864,240
Aug-18	7.77	0.015	0.031	1.9	0.1	1.15	1.48	30,960,464
Sep-18	7.85	0.016	0.039	2	0.09	1.18	1.51	27,366,894
Oct-18	7.89	0.019	0.039	3	0.12	1.15	1.48	22,912,342
Nov-18	7.89	0.022	0.036	2	0.08	1.38	1.72	19,902,443
Dec-18	7.7	0.021	0.031	1	0.08	1.42	1.76	17,775,398