


**DEPARTMENT OF ENVIRONMENTAL PROTECTION
LEAD AND COPPER ANALYSIS REPORT**

PWS I.D.: 4122000 PWS Name: Hanover Water Department Town: Hanover Sample Code¹: 1
 State Certified Laboratory: **ANALYTICAL BALANCE CORP.** Certified Lab #: **M-MA022**
 Lead Anal. Method: EPA 200.8 Lead Detection Limit: 0.001 mg/L Copper Anal. Method: EPA 200.8 Copper Detection Limit: 0.02mg/L
 # of Samples Required¹: 10 # of Samples Submitted¹: 17 90th Percentile Lead¹: 90th Percentile Copper¹:

Lab Sample ID	Collection Date	Sample Collection Code ¹	DEP Approved Sample Site ²	Lead Result (mg/L)	Lead Analysis Date	Copper Result (mg/L)	Copper Analysis Date
0120379-01	01/04/01	<u>2</u>	31 Tilden Road	0.001	1/11/01	0.745 ✓	1/11/01
0120379-02	01/04/01	<u>2</u>	24 Briarwood Drive	0.003 ✓	1/11/01	0.664 ✓	1/11/01
0120379-03	01/04/01	<u>2</u>	14 Maple Avenue	0.002 ✓	1/11/01	0.560 ✓	1/11/01

Sample Code		PLEASE NOTE THE FOLLOWING:
1	First Sampling Period	Water suppliers should mail TWO COPIES of this form to the DEP Regional Office within 10 days after the end of the reporting period. ¹ This section is to be filled out by the water supplier. ² See DEP Lead & Copper sampling plan for approved sampling locations.
2	Second Sampling Period	
3	Reduced - Annual	
4	Reduced - Every Three Years	
5	LSL Replacement Program	
6	Demonstration	

Remarks: _____

 19 Jan 01
 Water Supplier or Laboratory Director Signature / Date

**DEPARTMENT OF ENVIRONMENTAL PROTECTION
LEAD AND COPPER ANALYSIS REPORT**

PWS I.D.: 4122000 PWS Name: Hanover Water Department Town: Hanover Sample Code¹: 1
 State Certified Laboratory: **ANALYTICAL BALANCE CORP.** Certified Lab #: **M-MA022**
 Lead Anal. Method: EPA 200.8 Lead Detection Limit: 0.001 mg/L Copper Anal. Method: EPA 200.8 Copper Detection Limit: 0.02mg/L
 # of Samples Required¹: 10 # of Samples Submitted¹: 10 90th Percentile Lead¹: 0.032 90th Percentile Copper¹: 0.11

Lab Sample ID	Collection Date	Sample Collection Code ¹	DEP Approved Sample Site ²	Lead Result (mg/L)	Lead Analysis Date	Copper Result (mg/L)	Copper Analysis Date
0120491-01	01/09/01	<u>1</u>	Center School Drinking Foundation	0.032	1/11/01	0.89	1/11/01
0120491-02	01/09/01	<u>1</u>	Cedar School Prep. Sink	0.005	1/11/01	0.25	1/11/01
0120491-03	01/04/01	<u>2</u>	152 Long Water Drive	0.002	1/11/01	0.34	1/11/01
0120491-04	01/08/01	<u>2</u>	40 Saltwinds Drive	0.002	1/11/01	0.39	1/11/01
0120491-05	01/05/01	<u>2</u>	52 Saltwinds Drive	ND	1/11/01	0.11	1/11/01

Sample Code		PLEASE NOTE THE FOLLOWING:
1	First Sampling Period	Water suppliers should mail TWO COPIES of this form to the DEP Regional Office within 10 days after the end of the reporting period. ¹ This section is to be filled out by the water supplier. ² See DEP Lead & Copper sampling plan for approved sampling locations.
2	Second Sampling Period	
3	Reduced - Annual	
4	Reduced - Every Three Years	
5	LSL Replacement Program	
6	Demonstration	

Remarks: Sample 0120491-01 exceeds MCL for Lead.

[Signature] 19 Jan. 01
 Water Supplier or Laboratory Director Signature / Date


**DEPARTMENT OF ENVIRONMENTAL PROTECTION
LEAD AND COPPER ANALYSIS REPORT**

PWS I.D.: <u>4122000</u>	PWS Name: <u>Hanover Water Dept.</u>	Town: <u>Hanover</u>	Sample Code ¹ : <u>1</u>
State Certified Laboratory: ANALYTICAL BALANCE CORP.		Certified Lab #: M-MA022	
Lead Anal. Method: EPA 200.8	Lead Detection Limit: 0.001 mg/L	Copper Anal. Method: EPA 200.8	Copper Detection Limit: 0.02mg/L
# of Samples Required ¹ : <u>10</u>	# of Samples Submitted ¹ :	90 th Percentile Lead ¹ :	90 th Percentile Copper ¹ :

Lab Sample ID	Collection Date	Sample Collection Code ¹	DEP Approved Sample Site ²	Lead Result (mg/L)	Lead Analysis Date	Copper Result (mg/L)	Copper Analysis Date
121096-01	2/1/01	<u>1</u>	Center School Bubbler Auditorium	0.016	2/5/01	0.990 \	2/5/01
121096-02	2/1/01	<u>1</u>	Center School Kitchen Faucet	0.016	2/5/01	1.140	2/5/01
121096-03	2/1/01	<u>1</u>	Center School Bubbler Room #2	0.009	2/5/01	1.340	2/5/01
121096-04	2/1/01	<u>1</u>	Center School Bubbler Library	0.001	2/5/01	0.900	2/5/01
121096-05	2/1/01	<u>1</u>	Center School Room #5	0.003	2/5/01	1.550	2/5/01
121096-06	2/1/01	<u>1</u>	Center School Room #3	0.004	2/5/01	1.980	2/5/01
121096-07	2/1/01	<u>1</u>	# 1 Broadway Well # 4122000-06G	ND	2/5/01	0.055	2/5/01
121096-08	2/1/01	<u>1</u>	# 1 Hanover St. Well # 4122000-04G	ND	2/5/01	0.021	2/5/01
121096-09	2/1/01	<u>1</u>	Pond St. Water Treatment	ND	2/5/01	0.028	2/5/01
121096-10	2/1/01	<u>1</u>	Plant # 4122000-03G, 05G, 08G	ND	2/5/01	0.028	2/5/01

Sample Code		PLEASE NOTE THE FOLLOWING:
1	First Sampling Period	<p>Water suppliers should mail TWO COPIES of this form to the DEP Regional Office within 10 days after the end of the reporting period.</p> <p>¹ This section is to be filled out by the water supplier.</p> <p>² See DEP Lead & Copper sampling plan for approved sampling locations.</p>
2	Second Sampling Period	
3	Reduced - Annual	
4	Reduced - Every Three Years	
5	LSL Replacement Program	
6	Demonstration	

Remarks: Samples 21096-03,05,06 exceed MCL for Copper & 01,02 exceed MCL for Lead


Water Supplier or Laboratory Director Signature / Date 7 Feb. 01


**DEPARTMENT OF ENVIRONMENTAL PROTECTION
LEAD AND COPPER ANALYSIS REPORT**

PWS I.D.: <u>4122000</u>		PWS Name: Hanover Water Dept.		Town: Hanover		Sample Code ¹ : <u>1</u>	
State Certified Laboratory: ANALYTICAL BALANCE CORP.						Certified Lab #: M-MA022	
Lead Anal. Method: EPA 200.8		Lead Detection Limit: 0.001 mg/L		Copper Anal. Method: EPA 200.8		Copper Detection Limit: 0.02mg/L	
# of Samples Required ¹ : <u>10</u>		# of Samples Submitted ¹ :		90 th Percentile Lead ¹ :		90 th Percentile Copper ¹ :	

Lab Sample ID	Collection Date	Sample Collection Code ¹	DEP Approved Sample Site ²	Lead Result (mg/L)	Lead Analysis Date	Copper Result (mg/L)	Copper Analysis Date
121096-11	2/1/01	<u>2</u>	348 Old Farm Road	0.007	2/5/01	0.670	2/5/01

Sample Code		PLEASE NOTE THE FOLLOWING:
1	First Sampling Period	<p>Water suppliers should mail TWO COPIES of this form to the DEP Regional Office within 10 days after the end of the reporting period.</p> <p>¹ This section is to be filled out by the water supplier.</p> <p>² See DEP Lead & Copper sampling plan for approved sampling locations.</p>
2	Second Sampling Period	
3	Reduced - Annual	
4	Reduced - Every Three Years	
5	LSL Replacement Program	
6	Demonstration	

Remarks: _____



 Water Supplier or Laboratory Director Signature / Date


**DEPARTMENT OF ENVIRONMENTAL PROTECTION
LEAD AND COPPER ANALYSIS REPORT**

PWS I.D.: <u>4122000</u>	PWS Name: <u>Hanover Water Dept.</u>	Town: <u>Hanover</u>	Sample Code ¹ : <u>1</u>
State Certified Laboratory: ANALYTICAL BALANCE CORP.		Certified Lab #: M-MA022	
Lead Anal. Method: EPA 200.8	Lead Detection Limit: 0.001 mg/L	Copper Anal. Method: EPA 200.8	Copper Detection Limit: 0.001 mg/L
# of Samples Required ¹ : <u>10</u>	# of Samples Submitted ¹ :	90 th Percentile Lead ¹ :	90 th Percentile Copper ¹ :

Lab Sample ID	Collection Date	Sample Collection Code ¹	DEP Approved Sample Site ²	Lead Result (mg/L)	Lead Analysis Date	Copper Result (mg/L)	Copper Analysis Date
22179	3/15/2001	<u>1</u>	Center School Bubbler-Auditorium	ND	3/16/2001	0.102	3/16/2001

Sample Code	PLEASE NOTE THE FOLLOWING:
1 First Sampling Period	<p>Water suppliers should mail TWO COPIES of this form to the DEP Regional Office within 10 days after the end of the reporting period.</p> <p>¹ This section is to be filled out by the water supplier.</p> <p>² See DEP Lead & Copper sampling plan for approved sampling locations.</p>
2 Second Sampling Period	
3 Reduced - Annual	
4 Reduced - Every Three Years	
5 LSL Replacement Program	
6 Demonstration	

Remarks: _____


 Water Supplier or Laboratory Director Signature / Date

**DEPARTMENT OF ENVIRONMENTAL PROTECTION
LEAD AND COPPER ANALYSIS REPORT**

PWS I.D.: <u>4122000</u>	PWS Name: <u>Hanover Water Dept.</u>	Town: <u>Hanover</u>	Sample Code ¹ : <u>1</u>
State Certified Laboratory: ANALYTICAL BALANCE CORP.		Certified Lab #: M-MA022	
Lead Anal. Method: EPA 200.8	Lead Detection Limit: 0.001 mg/L	Copper Anal. Method: EPA 200.8	Copper Detection Limit: 0.001 mg/L
# of Samples Required ¹ : <u>10</u>	# of Samples Submitted ¹ :	90 th Percentile Lead ¹ :	90 th Percentile Copper ¹ :

Lab Sample ID	Collection Date	Sample Collection Code ¹	DEP Approved Sample Site ²	Lead Result (mg/L)	Lead Analysis Date	Copper Result (mg/L)	Copper Analysis Date
22307	3/12/2001	<u>2</u>	433 King St.	0.002	3/22/2001	0.349	3/22/2001

Sample Code	PLEASE NOTE THE FOLLOWING:
1 First Sampling Period	<p>Water suppliers should mail TWO COPIES of this form to the DEP Regional Office within 10 days after the end of the reporting period.</p> <p>¹ This section is to be filled out by the water supplier.</p> <p>² See DEP Lead & Copper sampling plan for approved sampling locations.</p>
2 Second Sampling Period	
3 Reduced - Annual	
4 Reduced - Every Three Years	
5 I SL Replacement Program	
6 Demonstration	

Remarks: _____

R. J. S. S. D. 26 March 01
Water Supplier or Laboratory Director Signature / Date

**DEPARTMENT OF ENVIRONMENTAL PROTECTION
LEAD AND COPPER ANALYSIS REPORT**

PWS I.D.: <u>4122000</u>		PWS Name: <u>Hanover Water Dept.</u>		Town: <u>Hanover</u>		Sample Code ¹ :	
State Certified Laboratory: ANALYTICAL BALANCE CORP.				Certified Lab #: M-MA022			
Lead Anal. Method: EPA 200.8		Lead Detection Limit: 0.001 mg/L		Copper Anal. Method: EPA 200.8		Copper Detection Limit: 0.001mg/L	
# of Samples Required ¹ :		# of Samples Submitted ¹ :		90 th Percentile Lead ¹ :		90 th Percentile Copper ¹ :	

Lab Sample ID	Collection Date	Sample Collection Code ¹	DEP Approved Sample Site ²	Lead Result (mg/L)	Lead Analysis Date	Copper Result (mg/L)	Copper Analysis Date
24671-01	6/05/01	/	31 Tilden Lane	ND	6/12/01	0.576	6/12/01
24671-02	6/05/01	/	40 Saltwind Drive	0.005	6/12/01	0.375	6/12/01
24671-03	6/05/01	/	152 Longwater Drive	0.006	6/12/01	0.753	6/12/01
24671-04	6/05/01	/	14 Maple Ave	0.006	6/12/01	0.775	6/12/01
24671-05	6/05/01	/	24 Briarwood Drive	0.002	6/12/01	0.494	6/12/01
24671-06	6/05/01	/	348 Old Farm Road	0.008	6/12/01	0.728	6/12/01
24671-07	6/05/01	/	52 Saltwind Drive	0.002	6/12/01	0.291	6/12/01

Sample Code	PLEASE NOTE THE FOLLOWING:
1 First Sampling Period	<p>Water suppliers should mail TWO COPIES of this form to the DEP Regional Office within 10 days after the end of the reporting period.</p> <p>¹ This section is to be filled out by the water supplier.</p> <p>² See DEP Lead & Copper sampling plan for approved sampling locations.</p>
2 Second Sampling Period	
3 Reduced - Annual	
4 Reduced - Every Three Years	
5 LSL Replacement Program	
6 Demonstration	

Remarks: _____


 18 June 01
 Water Supplier or Laboratory Director Signature / Date

Page 1 of 1

**DEPARTMENT OF ENVIRONMENTAL PROTECTION
LEAD AND COPPER ANALYSIS REPORT**

PWS ID: 4122000 PWS Name: Hanover Water Dept. Town: Hanover Sample Code:
 State Certified Laboratory: ANALYTICAL BALANCE CORP. Certified Lab #: M-MA022
 Lead Anal. Method: EPA 200.8 Lead Detection Limit: 0.001 mg/L Copper Anal. Method: EPA 200.8 Copper Detection Limit: 0.001 mg/L
 # of Samples Required¹: # of Samples Submitted²: 90th Percentile Lead¹: 90th Percentile Copper¹:

Lab Sample ID	Collection Date	Sample Collection Code ¹	DEP Approved Sample Site ²	Lead Result (mg/L)	Lead Analysis Date	Copper Result (mg/L)	Copper Analysis Date
24672	6/06/01		338 Whiting Street	0.008	6/12/01	0.732	6/12/01

Sample Code		PLEASE NOTE THE FOLLOWING:
1	First Sampling Period	Water suppliers should mail TWO COPIES of this form to the DEP Regional Office within 10 days after the end of the reporting period. ¹ This section is to be filled out by the water supplier. ² See DEP Lead & Copper sampling plan for approved sampling locations.
2	Second Sampling Period	
3	Reduced - Annual	
4	Reduced - Every Three Years	
5	LSL Replacement Program	
6	Demonstration	

Remarks: _____


 Water Supplier or Laboratory Director Signature / Date

Page 1 of 1


**DEPARTMENT OF ENVIRONMENTAL PROTECTION
LEAD AND COPPER ANALYSIS REPORT**

PWS I.D.: 4122000		PWS Name: Hanover Water Dept.		Town: Hanover		Sample Code ¹ :	
State Certified Laboratory: ANALYTICAL BALANCE CORP.				Certified Lab #: M-MA022			
Lead Anal. Method: EPA 200.8		Lead Detection Limit: 0.001 mg/L		Copper Anal. Method: EPA 200.8		Copper Detection Limit: 0.001mg/L	
# of Samples Required ¹ :		# of Samples Submitted ¹ :		90 th Percentile Lead ¹ :		90 th Percentile Copper ¹ :	

Lab Sample ID	Collection Date	Sample Collection Code ¹	DEP Approved Sample Site ²	Lead Result (mg/L)	Lead Analysis Date	Copper Result (mg/L)	Copper Analysis Date
24953-01	6/13/01		Cedar School - kitchen	0.004	6/27/01	0.308	6/27/01
24953-02	6/13/01		Center School - Bubblor	0.001	6/27/01	0.509	6/27/01
24953-03	6/13/01		443 King Street	ND	6/27/01	0.100	6/27/01

Sample Code		PLEASE NOTE THE FOLLOWING:
1	First Sampling Period	<p>Water suppliers should mail TWO COPIES of this form to the DEP Regional Office within 10 days after the end of the reporting period.</p> <p>¹ This section is to be filled out by the water supplier.</p> <p>² See DEP Lead & Copper sampling plan for approved sampling locations.</p>
2	Second Sampling Period	
3	Reduced - Annual	
4	Reduced - Every Three Years	
5	LSL Replacement Program	
6	Demonstration	

Remarks: _____


 2 July '01
 Water Supplier or Laboratory Director Signature / Date

Page 1 of 1


**DEPARTMENT OF ENVIRONMENTAL PROTECTION
LEAD AND COPPER ANALYSIS REPORT**

PWS I.D.: <u>4122000</u>		PWS Name: <u>Hanover Water Dept.</u>		Town: <u>Hanover</u>		Sample Code ¹ :	
State Certified Laboratory: ANALYTICAL BALANCE CORP.				Certified Lab #: M-MA022			
Lead Anal. Method: EPA 200.8		Lead Detection Limit: 0.001 mg/L		Copper Anal. Method: EPA 200.8		Copper Detection Limit: 0.001mg/L	
# of Samples Required: <u>10</u>		# of Samples Submitted: <u>10</u>		90 th Percentile Lead: <u>0.005</u>		90 th Percentile Copper: <u>0.847</u>	

Lab Sample ID	Collection Date	Sample Collection Code ¹	DEP Approved Sample Site ²	Lead Result (mg/L)	Lead Analysis Date	Copper Result (mg/L)	Copper Analysis Date
27229-01	8/14/01		31 Tilden Road	ND	8/17/01	0.593	8/17/01
27229-02	8/15/01		24 Briarwood Drive	0.002	8/17/01	0.43	8/17/01
27229-03	8/14/01		14 Maple Avenue	0.003	8/17/01	0.847	8/17/01
27229-04	8/14/01		152 Longwater Drive	0.006	8/17/01	0.7	8/17/01
27229-05	8/15/01		40 Saltwinds Drive	0.004	8/17/01	0.361	8/17/01
27229-06	8/15/01		52 Saltwinds Drive	0.001	8/17/01	0.273	8/17/01
27229-07	8/14/01		348 Old Farm Road	0.003	8/17/01	0.271	8/17/01
27229-08	8/15/01		443 King Street	0.001	8/17/01	0.817	8/17/01

Sample Code	PLEASE NOTE THE FOLLOWING:
1 First Sampling Period	<p>Water suppliers should mail TWO COPIES of this form to the DEP Regional Office within 10 days after the end of the reporting period.</p> <p>¹ This section is to be filled out by the water supplier.</p> <p>² See DEP Lead & Copper sampling plan for approved sampling locations.</p>
2 Second Sampling Period	
3 Reduced - Annual	
4 Reduced - Every Three Years	
5 LSL Replacement Program	
6 Demonstration	

Remarks: _____


22 Aug. 01
 Water Supplier or Laboratory Director Signature / Date

Page 1 of 1


**DEPARTMENT OF ENVIRONMENTAL PROTECTION
LEAD AND COPPER ANALYSIS REPORT**

PWS I.D.: 4122000		PWS Name: Hanover Water Dept.		Town: Hanover		Sample Code ¹ :	
State Certified Laboratory: ANALYTICAL BALANCE CORP.				Certified Lab #: M-MA022			
Lead Anal. Method: EPA 200.8		Lead Detection Limit: 0.001 mg/L		Copper Anal. Method: EPA 200.8		Copper Detection Limit: 0.001mg/L	
# of Samples Required ¹ :		# of Samples Submitted ¹ :		90 th Percentile Lead ¹ :		90 th Percentile Copper ¹ :	

Lab Sample ID	Collection Date	Sample Collection Code ¹	DEP Approved Sample Site ²	Lead Result (mg/L)	Lead Analysis Date	Copper Result (mg/L)	Copper Analysis Date
28244-01	9/13/01		Center School - bubbler	0.005	9/18/01	1.08	9/18/01
28244-02	9/13/01		Cedar Elementary - kitchen	0.003	9/18/01	0.559	9/18/01

Sample Code		PLEASE NOTE THE FOLLOWING:
1	First Sampling Period	<p>Water suppliers should mail TWO COPIES of this form to the DEP Regional Office within 10 days after the end of the reporting period.</p> <p>¹ This section is to be filled out by the water supplier.</p> <p>² See DEP Lead & Copper sampling plan for approved sampling locations.</p>
2	Second Sampling Period	
3	Reduced - Annual	
4	Reduced - Every Three Years	
5	LSL Replacement Program	
6	Demonstration	

Remarks: _____

 19 Sept. 01
 Water Supplier or Laboratory Director Signature / Date

Page 1 of 1


**DEPARTMENT OF ENVIRONMENTAL PROTECTION
LEAD AND COPPER ANALYSIS REPORT**

PWS ID: <u>4122000</u>	PWS Name: <u>Hanover Water Department</u>	Town: <u>Hanover</u>	Sample Code ¹ : _____
State Certified Laboratory: ANALYTICAL BALANCE CORP.		Certified Lab #: M-MA022	
Lead Anal. Method: <u>SM3113 B</u>	Lead Detection Limit: <u>0.001 mg/L</u>	Copper Anal. Method: <u>EPA 200.8</u>	Copper Detection Limit: <u>0.02 mg/L</u>
# of Samples Required ¹ : <u>10</u>	# of Samples Submitted ¹ : <u>10</u>	90 th Percentile Lead ¹ : <u>.009</u>	90 th Percentile Copper ¹ : <u>1.15</u>

Lab Sample ID	Collection Date	Sample Collection Code ¹	DEP Approved Sample Site ²	Lead Result (mg/L)	Lead Analysis Date	Copper Result (mg/L)	Copper Analysis Date
30528-01	11/15/01		348 Old Farm Road	0.001	11/21/01	0.15	11/21/01
30528-02	11/13/01		31 Tilden Road	0.001	11/21/01	0.31	11/21/01
30528-03	11/15/01		24 Briarwood Drive	0.002	11/21/01	1.18	11/21/01

Sample Code	PLEASE NOTE THE FOLLOWING:
1 First Sampling Period	<p>Water suppliers should mail TWO COPIES of this form to the DEP Regional Office within 10 days after the end of the reporting period.</p> <p>¹ This section is to be filled out by the water supplier.</p> <p>² See DEP Lead & Copper sampling plan for approved sampling locations.</p>
2 Second Sampling Period	
3 Reduced - Annual	
4 Reduced - Every Three Years	
5 LSL Replacement Program	
6 Demonstration	

Remarks: _____


26 Nov. 01
 Water Supplier or Laboratory Director Signature / Date

**DEPARTMENT OF ENVIRONMENTAL PROTECTION
LEAD AND COPPER ANALYSIS REPORT**

PWS I.D.: 4122000 PWS Name: Hanover Water Dept Town: Hanover Sample Code¹: _____

State Certified Laboratory: **ANALYTICAL BALANCE CORP.** Certified Lab #: **M-MA022**


Lead Anal. Method: SM 3113 B Lead Detection Limit: 0.001 mg/L Copper Anal. Method: EPA 200.8 Copper Detection Limit: 0.02 mg/L

of Samples Required¹: 10 # of Samples Submitted¹: 10 90th Percentile Lead¹: .009 90th Percentile Copper¹: 1.15

Lab Sample ID	Collection Date	Sample Collection Code ¹	DEP Approved Sample Site ²	Lead Result (mg/L)	Lead Analysis Date	Copper Result (mg/L)	Copper Analysis Date
30297-01	11/13/01		14 Maple Ave	0.003	11/19/01	0.90	11/19/01
30297-02	11/13/01		443 King Street	ND	11/19/01	0.96	11/19/01
30297-03	11/13/01		52 Saltwind Drive	0.004	11/19/01	0.36	11/19/01

Sample Code		PLEASE NOTE THE FOLLOWING:
1	First Sampling Period	<p>Water suppliers should mail TWO COPIES of this form to the DEP Regional Office within 10 days after the end of the reporting period.</p> <p>¹ This section is to be filled out by the water supplier.</p> <p>² See DEP Lead & Copper sampling plan for approved sampling locations.</p>
2	Second Sampling Period	
3	Reduced - Annual	
4	Reduced - Every Three Years	
5	LSL Replacement Program	
6	Demonstration	

Remarks: _____

 20 Nov 01
Water Supplier or Laboratory Director Signature / Date


**DEPARTMENT OF ENVIRONMENTAL PROTECTION
LEAD AND COPPER ANALYSIS REPORT**

PWS I.D.: <u>4122000</u>	PWS Name: <u>Hanover Water Dept.</u>	Town: <u>Hanover</u>	Sample Code ¹ :
State Certified Laboratory: ANALYTICAL BALANCE CORP.		Certified Lab #: M-MA022	
Lead Anal. Method: SM 3113 B	Lead Detection Limit: 0.001 mg/L	Copper Anal. Method: EPA 200.8	Copper Detection Limit: 0.02 mg/L
# of Samples Required ¹ : <u>10</u>	# of Samples Submitted ¹ : <u>10</u>	90 th Percentile Lead ¹ : <u>.009</u>	90 th Percentile Copper ¹ : <u>1.15</u>

Lab Sample ID	Collection Date	Sample Collection Code ¹	DEP Approved Sample Site ²	Lead Result (mg/L)	Lead Analysis Date	Copper Result (mg/L)	Copper Analysis Date
30645-01	11/27/01		40 Salt Woods	0.002	11/30/01	0.34	11/30/01
30645-02	11/15/01		152 Long Water Drive	0.022	11/30/01	0.47	11/30/01
30645-03	11/27/01		Cedar Elementary School - kitchen	0.006	11/30/01	0.90	11/30/01
30645-04	11/27/01		Cedar Elementary School - bubbler	0.009	11/30/01	1.15	11/30/01

Sample Code	PLEASE NOTE THE FOLLOWING:
1 First Sampling Period	<p>Water suppliers should mail TWO COPIES of this form to the DEP Regional Office within 10 days after the end of the reporting period.</p> <p>¹ This section is to be filled out by the water supplier.</p> <p>² See DEP Lead & Copper sampling plan for approved sampling locations.</p>
2 Second Sampling Period	
3 Reduced - Annual	
4 Reduced - Every Three Years	
5 LSL Replacement Program	
6 Demonstration	

Remarks: Sample 30645-02 exceeds the MCL for lead.


 Water Supplier or Laboratory Director Signature / Date