

**(LCR) Lead And Copper Report****Data Check - Unsigned**

PWS ID #: 4122000

City/Town: HANOVER

PWS Name: HANOVER WATER DEPT

PWS Class: COM

Primary Lab MA Cert #: M-MA022

Primary Lab Name: ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
9000	31 TILDEN LANE	RS	RESIDENTS	8/29/2017 06:30:00	O		

Sample Comments:

Analysis Comments:

Lab Sample ID:

171715101

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
LEAD	0.001	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.02	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
9000	52 SALTWIND DRIVE	RS	RESIDENTS	8/24/2017 08:30:00	O		

Sample Comments:

Analysis Comments:

Lab Sample ID:

171715102

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
LEAD	0.001	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.07	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
9000	48 BRIARWOOD DRIVE	RS	RESIDENTS	8/24/2017 06:00:00	O		

Sample Comments:

Analysis Comments:

Lab Sample ID:

171715103

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
LEAD	0.001	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.12	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
9000	75 EAST STREET	RS	RESIDENTS	8/24/2017 05:50:00	O		

Sample Comments:

Analysis Comments:

Lab Sample ID:

171715104

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
--------------	---------	------	------	--------------------	----------------	--------------------	-----------------

MDL = Method Detection Limit.

UOM = Unit of Measurement.

O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4122000

PWS Name: HANOVER WATER DEPT

9/11/2017 10:25:42 AM

Page 1 of 6

**(LCR) Lead And Copper Report****Data Check - Unsigned**

LEAD	0.002	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.08	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

<b>Location ID</b>	<b>Location</b>	<b>Routine/ Special:</b>	<b>Collected By:</b>	<b>Collection Date:</b>	<b>O/R/C:</b>	<b>Resubmit Reason:</b>	<b>Original Collection:</b>
9000	515 MAIN STREET	RS	RESIDENTS	8/29/2017 06:30:00	O		
<b>Sample Comments:</b>		<b>Analysis Comments:</b>		<b>Lab Sample ID:</b>			
				171715105			

<b>Contaminant:</b>	<b>Result:</b>	<b>UOM:</b>	<b>MDL:</b>	<b>Analytical Method:</b>	<b>Analysis Date:</b>	<b>Analytical Lab ID:</b>	<b>Analytical Lab:</b>
LEAD	0.010	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.19	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

<b>Location ID</b>	<b>Location</b>	<b>Routine/ Special:</b>	<b>Collected By:</b>	<b>Collection Date:</b>	<b>O/R/C:</b>	<b>Resubmit Reason:</b>	<b>Original Collection:</b>
9000	1010 MAIN STREET	RS	RESIDENTS	8/30/2017 06:30:00	O		
<b>Sample Comments:</b>		<b>Analysis Comments:</b>		<b>Lab Sample ID:</b>			
				171715106			

<b>Contaminant:</b>	<b>Result:</b>	<b>UOM:</b>	<b>MDL:</b>	<b>Analytical Method:</b>	<b>Analysis Date:</b>	<b>Analytical Lab ID:</b>	<b>Analytical Lab:</b>
LEAD	0.001	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.22	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

<b>Location ID</b>	<b>Location</b>	<b>Routine/ Special:</b>	<b>Collected By:</b>	<b>Collection Date:</b>	<b>O/R/C:</b>	<b>Resubmit Reason:</b>	<b>Original Collection:</b>
9000	24 SHINGLE MILL LANE	RS	RESIDENTS	8/29/2017 07:00:00	O		
<b>Sample Comments:</b>		<b>Analysis Comments:</b>		<b>Lab Sample ID:</b>			
				171715107			

<b>Contaminant:</b>	<b>Result:</b>	<b>UOM:</b>	<b>MDL:</b>	<b>Analytical Method:</b>	<b>Analysis Date:</b>	<b>Analytical Lab ID:</b>	<b>Analytical Lab:</b>
LEAD	0.001	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.53	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

<b>Location ID</b>	<b>Location</b>	<b>Routine/ Special:</b>	<b>Collected By:</b>	<b>Collection Date:</b>	<b>O/R/C:</b>	<b>Resubmit Reason:</b>	<b>Original Collection:</b>
9000	101. SHINGLE MILL LANE	RS	RESIDENTS	8/30/2017 07:00:00	O		
<b>Sample Comments:</b>		<b>Analysis Comments:</b>		<b>Lab Sample ID:</b>			
				171715108			

<b>Contaminant:</b>	<b>Result:</b>	<b>UOM:</b>	<b>MDL:</b>	<b>Analytical Method:</b>	<b>Analysis Date:</b>	<b>Analytical Lab ID:</b>	<b>Analytical Lab:</b>
LEAD	0.001	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.30	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

MDL = Method Detection Limit.

UOM = Unit of Measurement.

O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4122000

PWS Name: HANOVER WATER DEPT

9/11/2017 10:25:42 AM

Page 2 of 6

**(LCR) Lead And Copper Report****Data Check - Unsigned**

<b>Location ID</b>	<b>Location</b>	<b>Routine/ Special:</b>	<b>Collected By:</b>	<b>Collection Date:</b>	<b>O/R/C:</b>	<b>Resubmit Reason:</b>	<b>Original Collection:</b>
9000	111 GREAT ROCK ROAD	RS	RESIDENTS	8/29/2017 15:15:00	O		
<b>Sample Comments:</b>		<b>Analysis Comments:</b>		<b>Lab Sample ID:</b>			
				171715109			

<b>Contaminant:</b>	<b>Result:</b>	<b>UOM:</b>	<b>MDL:</b>	<b>Analytical Method:</b>	<b>Analysis Date:</b>	<b>Analytical Lab ID:</b>	<b>Analytical Lab:</b>
LEAD	0.006	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.56	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

<b>Location ID</b>	<b>Location</b>	<b>Routine/ Special:</b>	<b>Collected By:</b>	<b>Collection Date:</b>	<b>O/R/C:</b>	<b>Resubmit Reason:</b>	<b>Original Collection:</b>
9000	73 CLARK CIRCLE	RS	RESIDENTS	8/30/2017 17:25:00	O		
<b>Sample Comments:</b>		<b>Analysis Comments:</b>		<b>Lab Sample ID:</b>			
				171715110			

<b>Contaminant:</b>	<b>Result:</b>	<b>UOM:</b>	<b>MDL:</b>	<b>Analytical Method:</b>	<b>Analysis Date:</b>	<b>Analytical Lab ID:</b>	<b>Analytical Lab:</b>
LEAD	ND	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.17	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

<b>Location ID</b>	<b>Location</b>	<b>Routine/ Special:</b>	<b>Collected By:</b>	<b>Collection Date:</b>	<b>O/R/C:</b>	<b>Resubmit Reason:</b>	<b>Original Collection:</b>
9000	54 BAILEY ROAD	RS	RESIDENTS	8/30/2017 06:00:00	O		
<b>Sample Comments:</b>		<b>Analysis Comments:</b>		<b>Lab Sample ID:</b>			
				171715111			

<b>Contaminant:</b>	<b>Result:</b>	<b>UOM:</b>	<b>MDL:</b>	<b>Analytical Method:</b>	<b>Analysis Date:</b>	<b>Analytical Lab ID:</b>	<b>Analytical Lab:</b>
LEAD	ND	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.05	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

<b>Location ID</b>	<b>Location</b>	<b>Routine/ Special:</b>	<b>Collected By:</b>	<b>Collection Date:</b>	<b>O/R/C:</b>	<b>Resubmit Reason:</b>	<b>Original Collection:</b>
9000	40 BAILEY ROAD	RS	RESIDENTS	8/28/2017 05:30:00	O		
<b>Sample Comments:</b>		<b>Analysis Comments:</b>		<b>Lab Sample ID:</b>			
				171715112			

<b>Contaminant:</b>	<b>Result:</b>	<b>UOM:</b>	<b>MDL:</b>	<b>Analytical Method:</b>	<b>Analysis Date:</b>	<b>Analytical Lab ID:</b>	<b>Analytical Lab:</b>
LEAD	0.003	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.25	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

<b>Location ID</b>	<b>Location</b>	<b>Routine/ Special:</b>	<b>Collected By:</b>	<b>Collection Date:</b>	<b>O/R/C:</b>	<b>Resubmit Reason:</b>	<b>Original Collection:</b>
9000	31 BAILEY ROAD	RS	RESIDENTS	8/29/2017 15:00:00	O		

MDL = Method Detection Limit.

UOM = Unit of Measurement.

O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4122000

PWS Name: HANOVER WATER DEPT

9/11/2017 10:25:42 AM

Page 3 of 6

**(LCR) Lead And Copper Report****Data Check - Unsigned**

Sample Comments:

Analysis Comments:

Lab Sample ID:

171715113

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
LEAD	0.003	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.31	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
9000	89 CEDAR STREET	RS	RESIDENTS	8/29/2017 12:41:00	O		

Sample Comments:

Analysis Comments:

Lab Sample ID:

171715114

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
LEAD	0.006	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.23	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
9000	307 OLD FARM ROAD	RS	RESIDENTS	8/29/2017 07:00:00	O		

Sample Comments:

Analysis Comments:

Lab Sample ID:

171715115

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
LEAD	0.004	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.27	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
9000	339 OLD FARM ROAD	RS	RESIDENTS	8/24/2017 06:30:00	O		

Sample Comments:

Analysis Comments:

Lab Sample ID:

171715116

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
LEAD	0.002	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.17	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
9000	40 LONGWATER DRIVE	RS	RESIDENTS	8/30/2017 05:11:00	O		

Sample Comments:

Analysis Comments:

Lab Sample ID:

171715117

MDL = Method Detection Limit.

UOM = Unit of Measurement.

O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4122000

PWS Name: HANOVER WATER DEPT

9/11/2017 10:25:42 AM

Page 4 of 6

**(LCR) Lead And Copper Report****Data Check - Unsigned**

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
LEAD	0.001	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.13	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
9000	44 ASH LANE	RS	RESIDENTS	8/29/2017 05:30:00	O		
Sample Comments:		Analysis Comments:		Lab Sample ID: 171715118			

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
LEAD	0.005	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.25	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
9000	224 BRIARWOOD DRIVE	RS	RESIDENTS	8/29/2017 14:30:00	O		
Sample Comments:		Analysis Comments:		Lab Sample ID: 171715119			

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
LEAD	0.003	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.09	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
9000	20 TINDALE WAY	RS	RESIDENTS	8/30/2017 09:00:00	O		
Sample Comments:		Analysis Comments:		Lab Sample ID: 171715120			

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
LEAD	0.002	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.10	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
9000	443 KING STREET	RS	RESIDENTS	8/31/2017 07:30:00	O		
Sample Comments:		Analysis Comments:		Lab Sample ID: 171715121			

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
LEAD	0.002	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

MDL = Method Detection Limit.

UOM = Unit of Measurement.

O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4122000

PWS Name: HANOVER WATER DEPT

9/11/2017 10:25:42 AM

Page 5 of 6

**(LCR) Lead And Copper Report****Data Check - Unsigned**

COPPER	0.14	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
--------	------	------	------	-----------	----------	---------	-------------------------

<b>Location ID</b>	<b>Location</b>	<b>Routine/ Special:</b>	<b>Collected By:</b>	<b>Collection Date:</b>	<b>O/R/C:</b>	<b>Resubmit Reason:</b>	<b>Original Collection:</b>
9000	465 KING STREET	RS	RESIDENTS	8/31/2017 06:52:00	O		
<b>Sample Comments:</b>		<b>Analysis Comments:</b>		<b>Lab Sample ID:</b>			
				171715122			

<b>Contaminant:</b>	<b>Result:</b>	<b>UOM:</b>	<b>MDL:</b>	<b>Analytical Method:</b>	<b>Analysis Date:</b>	<b>Analytical Lab ID:</b>	<b>Analytical Lab:</b>
LEAD	0.001	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.07	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

<b>Location ID</b>	<b>Location</b>	<b>Routine/ Special:</b>	<b>Collected By:</b>	<b>Collection Date:</b>	<b>O/R/C:</b>	<b>Resubmit Reason:</b>	<b>Original Collection:</b>
9000	284 CIRCUIT STREET	RS	RESIDENTS	8/31/2017 07:30:00	O		
<b>Sample Comments:</b>		<b>Analysis Comments:</b>		<b>Lab Sample ID:</b>			
				171715123			

<b>Contaminant:</b>	<b>Result:</b>	<b>UOM:</b>	<b>MDL:</b>	<b>Analytical Method:</b>	<b>Analysis Date:</b>	<b>Analytical Lab ID:</b>	<b>Analytical Lab:</b>
LEAD	0.001	MG/L	0.001	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.14	MG/L	0.02	EPA 200.8	9/5/2017	M-MA022	ANALYTICAL BALANCE CORP

EDEP Transaction ID: 955124

MDL = Method Detection Limit.

UOM = Unit of Measurement.

O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4122000

PWS Name: HANOVER WATER DEPT

9/11/2017 10:25:42 AM

Page 6 of 6

**(LCR) Lead And Copper Report****Data Check - Unsigned**

PWS ID #: 4122000

City/Town: HANOVER

PWS Name: HANOVER WATER DEPT

PWS Class: COM

Primary Lab MA Cert #: M-MA022 Primary Lab Name: ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
9000	46 GREAT ROCK ROAD	RS	RESIDENTS	9/1/2017 07:00:00	O		
Sample Comments:		Analysis Comments:		Lab Sample ID: 171717701			

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
LEAD	0.001	MG/L	0.001	EPA 200.8	9/8/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.60	MG/L	0.02	EPA 200.8	9/8/2017	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
9000	184 LARCHMONT LANE	RS	RESIDENTS	9/1/2017 06:00:00	O		
Sample Comments:		Analysis Comments:		Lab Sample ID: 171717702			

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
LEAD	0.001	MG/L	0.001	EPA 200.8	9/8/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.04	MG/L	0.02	EPA 200.8	9/8/2017	M-MA022	ANALYTICAL BALANCE CORP

Location ID	Location	Routine/ Special:	Collected By:	Collection Date:	O/R/C:	Resubmit Reason:	Original Collection:
9000	90 DWELLEY AVENUE	RS	RESIDENTS	9/1/2017 05:00:00	O		
Sample Comments:		Analysis Comments:		Lab Sample ID: 171717703			

Contaminant:	Result:	UOM:	MDL:	Analytical Method:	Analysis Date:	Analytical Lab ID:	Analytical Lab:
LEAD	0.003	MG/L	0.001	EPA 200.8	9/8/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.46	MG/L	0.02	EPA 200.8	9/8/2017	M-MA022	ANALYTICAL BALANCE CORP

EDEP Transaction ID: 955125

MDL = Method Detection Limit.

UOM = Unit of Measurement.

O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4122000

PWS Name: HANOVER WATER DEPT

9/11/2017 10:25:44 AM

Page 1 of 1

**(LCR) Lead And Copper Report****Data Check - Unsigned**

PWS ID #: 4122000

City/Town: HANOVER

PWS Name: HANOVER WATER DEPT

PWS Class: COM

Primary Lab MA Cert #: M-MA022

Primary Lab Name: ANALYTICAL BALANCE CORP

<b>Location ID</b>	<b>Location</b>	<b>Routine/ Special:</b>	<b>Collected By:</b>	<b>Collection Date:</b>	<b>O/R/C:</b>	<b>Resubmit Reason:</b>	<b>Original Collection:</b>
9000	40 SALTWIND DRIVE	RS	RESIDENTS	9/13/2017 07:40:00	O		
<b>Sample Comments:</b>		<b>Analysis Comments:</b>		<b>Lab Sample ID:</b>			
				171767801			

<b>Contaminant:</b>	<b>Result:</b>	<b>UOM:</b>	<b>MDL:</b>	<b>Analytical Method:</b>	<b>Analysis Date:</b>	<b>Analytical Lab ID:</b>	<b>Analytical Lab:</b>
LEAD	ND	MG/L	0.001	EPA 200.8	9/21/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.03	MG/L	0.02	EPA 200.8	9/21/2017	M-MA022	ANALYTICAL BALANCE CORP

<b>Location ID</b>	<b>Location</b>	<b>Routine/ Special:</b>	<b>Collected By:</b>	<b>Collection Date:</b>	<b>O/R/C:</b>	<b>Resubmit Reason:</b>	<b>Original Collection:</b>
9000	18 TERESA LANE	RS	RESIDENTS	9/13/2017 04:00:00	O		
<b>Sample Comments:</b>		<b>Analysis Comments:</b>		<b>Lab Sample ID:</b>			
				171767802			

<b>Contaminant:</b>	<b>Result:</b>	<b>UOM:</b>	<b>MDL:</b>	<b>Analytical Method:</b>	<b>Analysis Date:</b>	<b>Analytical Lab ID:</b>	<b>Analytical Lab:</b>
LEAD	ND	MG/L	0.001	EPA 200.8	9/21/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.05	MG/L	0.02	EPA 200.8	9/21/2017	M-MA022	ANALYTICAL BALANCE CORP

<b>Location ID</b>	<b>Location</b>	<b>Routine/ Special:</b>	<b>Collected By:</b>	<b>Collection Date:</b>	<b>O/R/C:</b>	<b>Resubmit Reason:</b>	<b>Original Collection:</b>
9000	92 SHINGLE MILL LANE	RS	RESIDENTS	9/12/2017 16:30:00	O		
<b>Sample Comments:</b>		<b>Analysis Comments:</b>		<b>Lab Sample ID:</b>			
				171767803			

<b>Contaminant:</b>	<b>Result:</b>	<b>UOM:</b>	<b>MDL:</b>	<b>Analytical Method:</b>	<b>Analysis Date:</b>	<b>Analytical Lab ID:</b>	<b>Analytical Lab:</b>
LEAD	0.008	MG/L	0.001	EPA 200.8	9/21/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.28	MG/L	0.02	EPA 200.8	9/21/2017	M-MA022	ANALYTICAL BALANCE CORP

<b>Location ID</b>	<b>Location</b>	<b>Routine/ Special:</b>	<b>Collected By:</b>	<b>Collection Date:</b>	<b>O/R/C:</b>	<b>Resubmit Reason:</b>	<b>Original Collection:</b>
9000	19 ASPEN DRIVE	RS	RESIDENTS	9/13/2017 07:00:00	O		
<b>Sample Comments:</b>		<b>Analysis Comments:</b>		<b>Lab Sample ID:</b>			
				171767804			

<b>Contaminant:</b>	<b>Result:</b>	<b>UOM:</b>	<b>MDL:</b>	<b>Analytical Method:</b>	<b>Analysis Date:</b>	<b>Analytical Lab ID:</b>	<b>Analytical Lab:</b>
---------------------	----------------	-------------	-------------	---------------------------	-----------------------	---------------------------	------------------------

MDL = Method Detection Limit.

UOM = Unit of Measurement.

O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4122000

PWS Name: HANOVER WATER DEPT

9/25/2017 10:05:35 AM

Page 1 of 2



**(LCR) Lead And Copper Report****Data Check - Unsigned**

LEAD	0.001	MG/L	0.001	EPA 200.8	9/21/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.12	MG/L	0.02	EPA 200.8	9/21/2017	M-MA022	ANALYTICAL BALANCE CORP

<b>Location ID</b>	<b>Location</b>	<b>Routine/ Special:</b>	<b>Collected By:</b>	<b>Collection Date:</b>	<b>O/R/C:</b>	<b>Resubmit Reason:</b>	<b>Original Collection:</b>
9000	1327 BROADWAY	RS	RESIDENTS	9/12/2017 18:00:00	O		
<b>Sample Comments:</b>		<b>Analysis Comments:</b>		<b>Lab Sample ID:</b>			
				171767805			

<b>Contaminant:</b>	<b>Result:</b>	<b>UOM:</b>	<b>MDL:</b>	<b>Analytical Method:</b>	<b>Analysis Date:</b>	<b>Analytical Lab ID:</b>	<b>Analytical Lab:</b>
LEAD	0.001	MG/L	0.001	EPA 200.8	9/21/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.07	MG/L	0.02	EPA 200.8	9/21/2017	M-MA022	ANALYTICAL BALANCE CORP

<b>Location ID</b>	<b>Location</b>	<b>Routine/ Special:</b>	<b>Collected By:</b>	<b>Collection Date:</b>	<b>O/R/C:</b>	<b>Resubmit Reason:</b>	<b>Original Collection:</b>
9000	135 GREAT ROCK ROAD	RS	RESIDENTS	9/12/2017 07:00:00	O		
<b>Sample Comments:</b>		<b>Analysis Comments:</b>		<b>Lab Sample ID:</b>			
				171767806			

<b>Contaminant:</b>	<b>Result:</b>	<b>UOM:</b>	<b>MDL:</b>	<b>Analytical Method:</b>	<b>Analysis Date:</b>	<b>Analytical Lab ID:</b>	<b>Analytical Lab:</b>
LEAD	0.005	MG/L	0.001	EPA 200.8	9/21/2017	M-MA022	ANALYTICAL BALANCE CORP
COPPER	0.51	MG/L	0.02	EPA 200.8	9/21/2017	M-MA022	ANALYTICAL BALANCE CORP

EDEP Transaction ID: 958897

MDL = Method Detection Limit.

UOM = Unit of Measurement.

O/R/C = Original submittal or Resubmitted submittal or Confirmation sample.

PWS ID #: 4122000

PWS Name: HANOVER WATER DEPT

9/25/2017 10:05:35 AM

Page 2 of 2