



Per- and Polyfluoroalkyl Substances (PFAS) Report

Page 25 of 48

I. PWS INFORMATION: Please refer to your MassDEP Water Quality Sampling Schedule (WQSS) to help complete this form

PWS ID #: **4122000** City / Town: **HANOVER**
 PWS Name: **HANOVER WATER DEPARTMENT** PWS Class: **COM** ☒ **NTNC** ☐ **TNC** ☐

MassDEP Location (LOC) ID#	MassDEP Location Name	Sample Information		Date Collected	Collected By
RW-09G	PHILIP C. BEAL WELL #1	<input type="checkbox"/> (M)ultiple <input checked="" type="checkbox"/> (S)ingle	<input checked="" type="checkbox"/> (R)aw <input type="checkbox"/> (F)inished	04/26/21	N.M.
Routine or Special Sample	Original, Resubmitted or Confirmation Report	If Resubmitted Report, list below:			
<input checked="" type="checkbox"/> RS <input type="checkbox"/> SS	<input checked="" type="checkbox"/> Original <input type="checkbox"/> Resubmitted <input type="checkbox"/> Confirmation	(1) Reason for Resubmission		(2) Collection Date of Original Sample	
	<input type="checkbox"/> Resample <input type="checkbox"/> Reanalysis <input type="checkbox"/> Report Correction				
SAMPLE COMMENTS - Such as, if a Manifold/Multiple sample, list the source(s) that were on-line during sample collection or if this is a field reagent blank					

II. ANALYTICAL LABORATORY INFORMATION:

Primary Lab Cert. #: **M-MA086** Primary Lab Name: **Alpha Analytical Labs** Subcontracted? (Y/N) **Y**
 Analysis Lab Cert. #: **M-MA030** Analysis Lab Name: **Alpha Analytical Labs**
 If Analysis Lab is not certified by MassDEP or U.S. EPA, list certification authority:

Lab Method	Date Extracted	Date Analyzed	Dilution Factor	Lab Sample IDs#	
537.1	04/29/21	04/29/21	1	Primary Lab:	L2121200-13
				Subcontracted Lab:	L2121200-13

CAS#	REGULATED PFAS CONTAMINANTS	Result ¹ ng/L	Result ² Qualifier	MCL* ng/L	MDL ng/L	MRL ng/L
1763-23-1	Perfluorooctane Sulfonic Acid (PFOS)	2.04			0.457	1.86
335-67-1	Perfluorooctanoic Acid (PFOA)	4.01			0.579	1.86
355-46-4	Perfluorohexane Sulfonic Acid (PFHxS)	1.56	J		0.446	1.86
375-95-1	Perfluorononanoic Acid (PFNA)	ND			0.442	1.86
375-85-9	Perfluorooheptanoic Acid (PFHpA)	2.23			0.241	1.86
335-76-2	Perfluorodecanoic acid (PFDA)	ND			0.598	1.86
PFAS6 (sum of PFOS, PFOA, PFHxS, PFNA, PFHpA and PFDA; only include Results at or above the MRL; do not include estimated Results as described by a Result Qualifier in the next column)		8.28	--	20		
	UNREGULATED PFAS CONTAMINANTS					
375-73-5	Perfluorobutane sulfonic acid (PFBS)	1.08	J		0.264	1.86
307-55-1	Perfluorododecanoic acid (PFDoA)	ND			0.602	1.86
307-24-4	Perfluorohexanoic acid (PFHxA)	4.08			0.244	1.86
376-06-7	Perfluorotetradecanoic acid (PFTA)	ND			0.401	1.86
72629-94-8	Perfluorotridecanoic acid (PFTrDA)	ND			0.472	1.86
2058-94-8	Perfluoroundecanoic acid (PFUnA)	ND			0.397	1.86
2991-50-6	N-ethyl perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	ND			0.52	1.86
2355-31-9	N-methyl perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	ND			0.557	1.86
763051-92-9	11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11CI-PF3OUdS)	ND			0.195	1.86
756426-58-1	9-chlorohexadecafluoro-3-oxanone-1-sulfonic acid (9CI-PF3ONS)	ND			0.256	1.86
919005-14-4	4,8-dioxa-3H-perfluorononanoic acid (ADONA)	ND			0.067	1.86
13252-13-6	Hexafluoropropylene oxide dimer acid (HFPO-DA)	ND			0.42	1.86

¹ A field reagent blank (FRB) must be analyzed and reported on a separate PFAS form if any PFAS are detected above the MRL.² All qualifiers must be described under Lab Analysis Comments on page 2.